

DECLARATION OF PERFORMANCE | No.001

BS EN 1366-5 FIRE RESISTING SERVICE ENCLOSURE

Unique identification code of the product-type:	Harcom [®] Fire Resisting Service Enclosure
Intended use/es:	EN 1366-5 Fire Resisting Service Enclosure for 120 minutes Integrity and Insulation.
System/s of AVCP:	1
Harmonised standard:	BS EN12101-3
Notified body/ies:	Efectis France
Declared performance/s:	

Essential Characteristics	Performance	Harmonised Technical Specification
Integrity Insulation Mechanical Stability	EI120 (Ve Ho o>i) EI120 (Ve Ho i>o)	BS EN13501-2:2023

The performance of the product identified above is in conformity with the set of declared of performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of:



Name: Steve Harrison

Title: Managing Director

Signature: 

At/On: Central House, 25 Camperdown Street, London E1 8DZ
28/04/ 2026